


<b>AMENDMENT OF SOLICITATION/MODIFICATION OF CONTRACT</b>			1. Contract Number	Page of Pages 1      2	
2. Amendment/Modification Number DCFA-2008-R-0124-005		3. Effective Date 14-Mar-08		4. Requisition/Purchase Request No.	
5. Solicitation Caption					
6. Issued By: Office of Contracting and Procurement (Indicate Cluster Name) (Indicate Address, including Room/Suite Number) Washington, DC (Include Zip Code)		Code		7. Administered By (If other than line 6)	
8. Name and Address of Contractor (No. Street, city, country, state and ZIP Code)		(X)		9A. Amendment of Solicitation No. DCFA-2008-R-0124	
				9B. Dated (See Item 11) 2/27/2008	
				10A. Modification of Contract/Order No.	
				10B. Dated (See Item 13)	
Code		Facility			
11. THIS ITEM ONLY APPLIES TO AMENDMENTS OF SOLICITATIONS					
<input type="checkbox"/> The above numbered solicitation is amended as set forth in Item 14. The hour and date specified for receipt of Offers <input type="checkbox"/> is extended. <input checked="" type="checkbox"/> is not extended. Offers must acknowledge receipt of this amendment prior to the hour and date specified in the solicitation or as amended, by one of the following methods: (a) By completing Items 8 and 15, and returning <u>1</u> copies of the amendment; (b) By acknowledging receipt of this amendment on each copy of the offer submitted; or (c) By separate letter or fax which includes a reference to the solicitation and amendment number. FAILURE OF YOUR ACKNOWLEDGEMENT TO BE RECEIVED AT THE PLACE DESIGNATED FOR THE RECEIPT OF OFFERS PRIOR TO THE HOUR AND DATE SPECIFIED MAY RESULT IN REJECTION OF YOUR OFFER. If by virtue of this amendment you desire to change an offer already submitted, such change may be made by letter or fax, provided each letter or telegram makes reference to the solicitation and this amendment, and is received prior to the opening hour and date specified.					
12. Accounting and Appropriation Data (If Required)					
13. THIS ITEM APPLIES ONLY TO MODIFICATIONS OF CONTRACTS/ORDERS, IT MODIFIES THE CONTRACT/ORDER NO. AS DESCRIBED IN ITEM 14					
(X) A. This change order is issued pursuant to: (Specify Authority)					
The changes set forth in Item 14 are made in the contract/order no. in item 10A.					
B. The above numbered contract/order is modified to reflect the administrative changes (such as changes in paying office, appropriation date, etc.) set forth in item 14, pursuant to the authority of 27 DCMR, Chapter 36, Section 3601.2.					
C. This supplemental agreement is entered into pursuant to authority of:					
D. Other (Specify type of modification and authority)					
<b>E. IMPORTANT:</b> Contractor <input type="checkbox"/> is not, <input checked="" type="checkbox"/> is required to sign this document and return _____ copies to the issuing office.					
14. Description of amendment/modification (Organized by UCF Section headings, including solicitation/contract subject matter where feasible.)					
Solicitation No. DCFA-2008-R-0124 is hereby amended as follows:					
(1) Section J. List of Attachments Delete "General Order 601.1 (Change Number 1), dated April 30, 1992, titled: Recording, Handling and Disposition of Property Coming into the Custody of the Department"					
(2). Additional Questions and Responses Attached on page 2.					
Except as provided herein, all terms and conditions of the document referenced in Item (9A or 10A) remain unchanged and in full force and effect					
15A. Name and Title of Signer (Type or print)			16A. Name of Contracting Officer Karen Hester		
15B. Name of Contractor		15C. Date Signed		16B. District of Columbia	
(Signature of person authorized to sign)				 (Signature of Contracting Officer)	
				16C. Date Signed 3/14/08	

1. Question: Paragraph C.5.5.5 of the RFP does not provide a minimum square footage for the Hazardous Material Area. Please provide minimum square footage required for this function.

Response: A minimum requirement for the Hazardous Material Area is 300 square feet.

2. Question: Paragraph C.5.1 of the RFP states "The foundation of the new facility must be built so that future vertical expansion is possible." Please provide more information, such as the size of the future expansion, etc., so that the foundation can be designed and/or sized accordingly.

Response: The foundations that are being installed for the current use of the warehouse should also be designed to accommodate additional vertical expansion if so desired in the future for additional warehousing or storage space.